



# JAIPUR METRO RAIL CORPORATION LIMITED

(A Govt. of Rajasthan undertaking)

## Directorate of Operations & Systems

3<sup>rd</sup> Floor, Administrative Building, Bhriugu Path, Mansarovar, Jaipur- 302020

Tel. No. 0141-2822106 (O), E-mail – edst@jaipurmetrorail.in



JAIPUR METRO

No.- F.2(73) JMRC/O&S/S&T/VRLA/2021-22/6012

Date:- 06.09.2022

To,  
All Prospective Bidders

### Corrigendum-1

**Name of Bid:** Supply, Installation, Testing, Commissioning & Dismantling of Maintenance Free Valve Regulated Lead Acid Batteries for UPS and SMPS Installed at JMRC

**Bid No.:** F.2(73) JMRC/O&S/S&T/VRLA/2021-22 Dated 22.08.2022

The following corrigendum may be deemed as an amendment in the Bid document of the above referred Bid. Concerned may participate accordingly.

Clause No.	Existing condition of Bid	Now may be read as:
2.5.8	Bidder should be listed in the approved list as "RDSO Approved vendor" of RDSO for Valve Regulated (sealed) Lead Acid Stationary Battery for S&T installations or he should be authorized dealer of one of the approved vendor in the said RDSO Approved vendor list. In case of authorized dealer, he should furnish the authorization certificate from the RDSO approved vendor. <b>RDSO vendors for Development orders will not be considered.</b>	Bidder should be listed in the approved list as "RDSO Approved vendor" of RDSO for Valve Regulated (sealed) Lead Acid Stationary Battery for S&T installations or he should have authorization letter from the approved vendor/vendors in the said RDSO approved vendor list for 2V, 120AH & 2V, 400AH battery. For 600AH battery authorization is not mandatory from RDSO approved vendor, but material to be supplied from any source and shall conform to Spec. No. IEC specification 60896-21 & 22 or latest. <b>RDSO vendors for Development orders will not be considered.</b>
3.1.4 (d)	All the charges for the RDSO inspection for battery 120 AH, 400 AH and third party inspection or JMRC for battery 600AH is to be borne by bidder. The documentary evidence for the RDSO & third party inspection or JMRC is to be submitted before supply of Batteries to JMRC.	All the charges for the RDSO inspection for battery 120 AH, 400 AH and third party inspection or JMRC for battery 600AH is to be borne by bidder. 600AH battery inspection will be done at OEM Factory Premises. The documentary evidence for the RDSO & third party inspection or JMRC is to be submitted before supply of Batteries to JMRC.

This corrigendum will be part of document. All other terms & conditions of the document will remain same.

*[Handwritten Signature]*  
06/09/2022

EXECUTIVE DIRECTOR (S&T)  
JAIPUR METRO RAIL CORPORATION LTD.



Registered Office: Admin Building, Metro Depot, Bhriugu Path, Mansarovar, Jaipur-302005

CIN: U60221RJ2010SGC030630

Website: www.transport.rajasthan.gov.in/jmrc