



JAIPUR METRO

**JAIPUR METRO RAIL CORPORATION LIMITED**

(A Govt. of Rajasthan undertaking)

**Directorate of Operations & Systems**

4<sup>th</sup> Floor, Administrative Building, Bhriгу Path, Mansarovar, Jaipur 302020

Tel. No. 0141-2822103 (O), E-mail: edtem@jaipurmetrorail.in

F.No. 2(281)/JMRC/O&S/TEM/2022-23/SITC of UPS Battery Bank/1262 Date: 03.07.2023

**Corrigendum - 01**

**Subject:** Corrigendum of NIB No. JMRC/O&S/EL/2023-24/NIB/016.

**Name of Work:** "Supply, Installation, Testing & Commissioning (SITC) of Battery bank for UPSs installed at Metro Stations of Phase-1A and Metro Depot of JMRC"

**UBN no.:** JMR2324GLOB00044

(A) In reference to above cited work and NIB, following corrigendum is hereby made in the bid document as following:

<b>Bid document reference</b>	<b>Existing</b>	<b>May be read as below</b>
Page 4 of 51, Section 1 Notice Inviting Bid(NIB), Key Details (8)	Last date and Time, venue for Physical submission of original DD/BC for Bid fee, e-Bid Processing fee and original EMD/Bid Security fee: 05.07.2023 at 14:00 hrs.	Last date and Time, venue for Physical submission of original DD/BC for Bid fee, e-Bid Processing fee and original EMD/Bid Security fee: 12.07.2023 at 14:00 hrs.
Page 5 of 51, Section 1 Notice Inviting Bid(NIB), Key Details (14)	Last date and Time for Online Submission of Bid: 05.07.2023 at 14:30 hrs.	Last date and Time for Submission of Bid: 12.07.2023 at 14:30 hrs.
Page 5 of 51, Section 1 Notice Inviting Bid(NIB), Key Details (15)	Time and date of Opening of Bid: 05.07.2023 at 15:00 hrs.	Time and date of Opening of Bid: 12.07.2023 at 15:00 hrs.
Page 23 of 51, Section 5 TECHNICAL SPECIFICATION and SCOPE OF WORK, 5.1 Technical Specification: 5.1.1 (Sr. No. 1)	<b>Description of Item:</b> SITC 12V 100AH battery bank for 20KVA UPS (UPS make: Numeric) with Connector/Lug and cable for battery terminal connections, complete in all respect. The battery shall be Valve Regulated Lead Acid (VRLA) Sealed Maintenance Free type with AGM (absorbent glass mat) technology.) Warranty: 24 Months Make: Amaron, Exide	<b>Description of Item:</b> SITC 12V 100AH battery bank for 20KVA UPS (UPS make: Numeric) with Connector/Lug and cable for battery terminal connections, complete in all respect. The battery shall be Valve Regulated Lead Acid (VRLA) Sealed Maintenance Free type with AGM (absorbent glass mat) technology.) Warranty: 24 Months Make: HBL Nife, Exide, Faukawa, Amaraja, Amco
Page 23 of 51, Section 5 TECHNICAL SPECIFICATION and SCOPE OF WORK, 5.1 Technical Specification: 5.1.1 (Sr. No. 2)	<b>Description of Item:</b> SITC of 12V, 120AH, Valve Regulated Lead Acid (VRLA) sealed maintenance free (SMF) battery with 30 Minutes battery backup to each 2 x 40KVA Numeric Make UPSs. Each battery bank should be minimum 24000VAH capacity. Battery shall be in accordance with the relevant regulations. Make: Amaron, Exide	<b>Description of Item:</b> SITC of 12V, 120AH, Valve Regulated Lead Acid (VRLA) sealed maintenance free (SMF) battery with 30 Minutes battery backup to each 2 x 40KVA Numeric Make UPSs. Each battery bank should be minimum 24000VAH capacity. Battery shall be in accordance with the relevant regulations. Make: HBL Nife, Exide, Faukawa, Amaraja, Amco
Page 23 of 51, Section 5 TECHNICAL SPECIFICATION	<b>Description of Item:</b> SITC of 2V, 240AH cell (VRLA SMF Battery) with connector /lug and cable for battery terminal connections, complete in all	<b>Description of Item:</b> SITC of 2V, 240AH cell (VRLA SMF Battery) with connector /lug and cable for battery terminal connections, complete in all

03.07.23



JAIPUR METRO

**JAIPUR METRO RAIL CORPORATION LIMITED**

(A Govt. of Rajasthan undertaking)


**Directorate of Operations & Systems**

4<sup>th</sup> Floor, Administrative Building, Bhriugu Path, Mansarovar, Jaipur 302020

Tel. No. 0141-2822103 (O), E-mail: edtem@jaipurmetrorail.in

and SCOPE OF WORK, 5.1 Technical Specification: 5.1.1 (Sr. No. 3)	respect. 30minut battery backup to 2*80KVA UPS Riello make <b>Make:</b> Amaron, Exide	respect. 30minut battery backup to 2*80KVA UPS Riello make <b>Make:</b> HBL Nife, Exide, Faukawa, Amaraja, Amco
---	---	---

1. This corrigendum shall be part of Bid document.
2. Other terms and conditions of bid document shall remain unchanged.

  
03.07.20

**ED (Traction and E&M)**  
Jaipur Metro Rail Corporation Ltd