



JAIPUR METRO

JAIPUR METRO RAIL CORPORATION LIMITED

(A Govt. of Rajasthan undertaking)

Directorate of Operations & Systems

4th Floor, Administrative Building, Bhriugu Path, Mansarovar, Jaipur 302020

Tel. No. 0141-2822103 (O), E-mail: edtem@jaipurmetrorail.in

F.No. 2(294)/JMRC/O&S/TEM/2023-24/3870

Date: 10.09.2024

Corrigendum - 02

Subject: Corrigendum of NIB No. JMRC/O&S/EL/2024-25/NIB/011.

Name of Work: "Supply, Installation, Testing & Commissioning (SITC) works for Up-gradation of SCADA System including up-gradation of all Bay Control Unit (C264) and Bay Control and Protection unit (C264P) installed at both Mansarovar and Sindhi Camp RSS of JMRC Phase-1A"

UBN no.: JMR2425SLOB00065

In reference to above cited work and NIB, following corrigendum is hereby made in the bid document as following:

Bid document reference	Existing	May be read as below
Page 23 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.1	The Scope of works includes "Supply, Installation, Testing & Commissioning (SITC) works for Up-gradation of SCADA System (Make: Schneider) including up-gradation of all Bay Control Unit (C264, Make: Alstom), Bay Control and Protection unit (C264P, make: Schneider) installed in GIS and CRP and 132 KV, 33 KV and 25KV relays with firmware / software up-gradation of both Mansarovar and Sindhi Camp RSS of JMRC Phase-1A".	The Scope of works includes "Supply, Installation, Testing & Commissioning (SITC) works for Up-gradation of SCADA System (Make: Schneider) with upgradation of all Bay Control Unit (C264, Make: Alstom), Bay Control and Protection unit (C264P, make: Schneider) installed in GIS and CRP for both RSS as details specified in clause 5.2.26 including firmware / software up-gradation for 132 KV, 33 KV and 25KV relays, if required, at both Mansarovar and Sindhi Camp RSS of JMRC Phase-1A."
Page 23 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.9	Window version should be up-graded with latest version	Window version should be up-graded with latest version as per OEM.
Page 23 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.10	Up-graded window, software and other related software key/license should have life time warranty/lifetime validity for existing version.	Up-graded window, software and other related software key/license should have life time warranty/lifetime validity for upgraded version.
Page 24 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.23	LAN cable and Patch Cord with ferrule of all BCU and EFS for 132 KV, 33KV & 25 KV shall be included in this work.	Stands Deleted.
Page 26 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.26, Sr. No. 15 (at Column "New Version details required to be installed)	To be upgraded and Compatible with latest version as per OEM.	To be upgraded, if required and shall be Compatible with latest version as per OEM. The decision of Engineer-in charge shall be final.



JAIPUR METRO

JAIPUR METRO RAIL CORPORATION LIMITED

(A Govt. of Rajasthan undertaking)

Directorate of Operations & Systems

4th Floor, Administrative Building, Bhriгу Path, Mansarovar, Jaipur 302020

Tel. No. 0141-2822103 (O), E-mail: edtem@jaipurmetrorail.in

Bid document reference	Existing	May be read as below
Page 27 of 50, Section 5 SCOPE of Work, Clause 5.1, Sub clause 5.2.26, Sr. No. 17 (at Column "New Version details required to be installed)	To be upgraded and Compatible with latest version as per OEM.	To be upgraded, if required and shall be Compatible with latest version as per OEM. The decision of Engineer-in charge shall be final.

1. This corrigendum shall be part of Bid document.
2. Other terms and conditions of bid document shall remain unchanged.

ED (Traction and E&M)
Jaipur Metro Rail Corporation Ltd

Document certified by Om Prakash
<bixirax830@rehezb.com>.
Digitally Signed by OM
PRAKASH
Designation : Executive Director
Date :10-09-2024 10:04:44